

LFCDA

Eastern Command - Fire Safety
210 High Street South,
East Ham, London E6 3RS

LONDON FIRE AND CIVIL DEFENCE AUTHORITY

Chief Fire Officer and Chief Executive
B G Robinson CBE QFSM FIFireE

LONDON FIRE BRIGADE

Telephone 0207-587-2108
Facsimile 0207-587-2133
E-mail fseastham@lfcda.org.uk
My ref. FS/
Your ref.
Date 21/9/99

L. S. of Hackney,
District Surveyors Office,
City Rd.,
EC1V.
Z. A. O. - Lay Lane.

Dear Lay,
Ref. Access - L/O 87/89 Brighton Rd.,

The problem with the provision of hydrants,
in lieu of access in accordance with the Building
Regs. 1991 Part B. is as follows:-

a) Although the fire fighters may carry hose and the
remainder of the equipment to any incident,
there is no guarantee that there will be
sufficient water pressure at the hydrant to
enable fire-fighting to be carried out.

b) If at any time the water main is being
worked on or is not available for any other
reason, fire-fighting operations are put in
jeopardy.

Regards,
Bob

